




The State of New Hampshire
Department of Environmental Services



Michael P. Nolin
Commissioner

July 7, 2005

**LETTER OF CLOSURE for
LETTER OF DEFICIENCY #WSEB 04-076**

Carolyn Hager
Slope N Shore Club
P.O. Box 195
New London, NH 03257-0195

Subject: New London - Public Water System: Slope N Shore Club (EPA #1722020)

Dear Ms. Hager:

Based on a recent review of the file for Slope N Shore Club, the Department of Environmental Services (DES) has determined that the **Compliance Gross Alpha** result levels have been below the maximum contaminant level of **15 pCi/L** for over a year. Therefore, DES hereby closes Letter of Deficiency #WSEB 04-076, dated May 17, 2004 (the "LOD"). As such, the actions requested in the LOD are not enforceable at this time.

Based on the running annual average of the following contaminants, your schedule has been modified as follows:

Contaminant	FRDS code	Next Sampling Quarter/Year
Compliance gross alpha	4000	Q4 / 2012
Radium 226 & Radium 228	4010	Q4 / 2015

If you have any questions, please contact me at (603) 271-0659 or by e-mail at emcnaughten@des.state.nh.us.

Sincerely,

COPY
Betsy McNaughten

Betsy McNaughten

Monitoring and Enforcement Section

Water Supply Engineering Bureau

h:\wseb\enfmon\enforce\lods\chem mon\2004\2004 letters of closure\1722020 slope n shore 04-076 rad mcl dropped below.doc

encl: Master Sampling Schedule

cc: Gretchen R. Hamel, DES Legal Unit Administrator
John Benham, Pump Systems Inc., Primary Operator (w/ encl)
Town of New London Health Officer
EPA, Region 1
File

P.O. Box 95, 29 Hazen Drive, Concord, New Hampshire 03302-0095
Telephone: (603) 271-3139 • Fax: (603) 271-5171 • TDD Access: Relay NH 1-800-735-2964
DES Web site: www.des.nh.gov